



TECHNO TECH AQUA INDUSTRIES PVT. LTD.

FACTORY : 136 / F1, 2 ND PHASE, GIDC VAPI : 396 195.

Phone No. Mob. 09328963516, 18 , & 098251 49350,

technotech_services@yahoo.co.in, technotechaqua_ind@yahoo.in

ISO 9001-2015 CERTIFIED CO.

August 10, 2023

Water Analysis Report

CLIENT'S NAME : M/S LIONS CLUB
ADDRESS : SILVASSA
SUPPLIED BY : M/S LIONS CLUB

Organoleptic And Physical Parameters

SR.No.	Characteristic	(BIS STANDERD)	Results
01.	Colour (colour unit max)	2	1
02.	Order	Agreeable	Agreeable
03.	Test	Do	Do
04.	Turbidity(NTU) max	2	1
05.	Total Dissolved Solids (mg/l) max	300	25
06.	pH Values	6.5 to 8.5	7.3

GENERAL PARAMETERS

SR.No.	Characteristic		Results
01.	Barium as Ba (mg/l) max	1.0	-
02.	Copper as Cu(mg/l) max	0.05	-
03.	Iron as Fe(mg/l) max	0.1	0.02
04.	Manganese as Mn(mg/l) max	0.1	-
05.	Nitrate as NO ₃ (mg/l) max	45	1.6
06.	Floride as F(mg/l) max	1.0	-
07.	Zinc as Zn(mg/l) max	5	-
08.	Silver as Ag(mg/l) max	0.01	-
09.	Aluminum as Al(mg/l) max	0.03	-
10.	Chloride as Cl(mg/l) max	200	59
11.	Selenium as Se(mg/l) max	0.01	-
12.	Sulphate as SO ₄ (mg/l) max	200	51
13.	Alkalinity as HCO ₃ (mg/l) max	200	103
14.	Calcium as Ca(mg/l) max	75	38
15.	Magnesium as Mg(mg/l) max	30	21
16.	Sodium as Na(mg/l) max	200	51
17.	Residual free Chloride (mg/l) max	0.2	-
18.	Phenolic Compound as C ₆ H ₅ OH(mg/l) max	0.001	-
19.	Mineral Oil (mg/l) max	0.01	-
20.	Anionic Surface active agents as MBAS(mg/l)max	0.02	-
21.	Nitrite as NO ₂ (mg/l) max	0.02	-

N. S. Parvathi
22/08/23
PRINCIPAL

LIONS ENGLISH SCHOOL
SILVASSA

LIONS CLUB OF SILVASSA CHARITABLE TRUST

Amarayaman

SECRETARY

TOXIC SUBSTANCE

SR.No.	Characteristic	Requirement	Results
01.	Mercury as Hg(mg/l) max	0.001	ND
02.	Cadmium A Cd(mg/l) max	0.01	ND
03.	Arsenic as As(mg/l) max	0.05	ND
04.	Cyanide as CN(mg/l) max	0.05	ND
05.	Lead as Pb(mg/l) max	0.01	ND
06.	Chromium as Cr(mg/l) max	0.05	ND
07.	Nickel as Ni(mg/l) max	0.02	ND
08.	Polychlorinated biphenyle PCB	Not detectable	Not detectable
09.	Polynuclear aromatic Hydrocarbon	Not detectable	Not detectable

BACTERIOLOGICAL ANALYSIS

NUMBER OF BACTERIA PRESENT PER ML OF THE SAMPLE : NIL
(PLATE METHOD) AT 37 °C

NUMBER OF BACTERIA PRESENT PER ML OF THE SAMPLE : NIL
(PLATE METHOD) AT 20-22 °C

MOST PROBABLE NO OF COLIFORM BACILLI PRESENT PER : NIL
100 ML OF THE SAMPLE (M.P.N.)

Techno Tech Aqua Industries Pvt Ltd

SURAJA . SHUKLA

N. S. Barelch
24/08/23
PRINCIPAL
LIONS ENGLISH SCHOOL
SILVASSA

LIONS CLUB OF SILVASSA CHARITABLE TRUST

Anarayanan
SECRETARY

**UT ADMINISTRATION OF
DADRA & NAGAR HAVELI & DAMAN & DIU
DIRECTORATE OF MEDICAL & HEALTH SERVICES
O/o. CHIEF MEDICAL OFFICER (CMO)
(SANITATION & HYGIENE SECTION - D&NH)**


No. CMO/DNH/SI/NOC/2023/3223

Date: 21.08.2023.

CERTIFICATE

This is to certify that **Lions English School** (Run by Lions Club of Silvassa Charitable Trust), Sanjibhai Delkar Marg, Silvassa – UT of Dadra & Nagar Haveli and Daman & Diu, was physically inspected and found fit from Sanitation and Hygiene point of view.

This certificate is valid from **21/08/2023 to 20/08/2024**.



D.K. Makwana
(Dr. D. K. Makwana)
Chief Medical Officer (CMO)
Dadra & Nagar Haveli

To,
Lions English School
Sanjibhai Delkar Marg,
Silvassa, D&NH.

LIONS CLUB OF SILVASSA CHARITABLE TRUST

Anandaraman
SECRETARY

Nobazeech
23/08/23
PRINCIPAL
LIONS ENGLISH SCHOOL
SILVASSA